

182200781
C-6

Noncompliance Letter

City of Plummer

880 C street

Plummer Idaho 83851



This letter is a follow up on a noncompliance report that the City of Plummer called in on 01/24/2017 for the actions on 01/11/17 for maximum daily limit of Ammonia and E-coli.

The City of Plummer Violated the maximum daily limits of Ammonia and E-coli due to the weather conditions for the prior weeks following the samples. The Wastewater plant had airlines, actuator valves, and Pumps freeze at night due to cold weather. This made it impossible for the air cycles to operator and let the microorganisms properly do what they do.

The City turned the air cycle up so the down time is not as long hoping it doesn't give it time to freeze. We have a company coming to check the air dryer to prevent any moisture from entering the airlines.

A handwritten signature in blue ink, consisting of a stylized 'L' followed by a series of loops and a horizontal line.

Leonard Johnson

City of Plummer

Operator

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

1/24/2017

Time of Call

8:22 AM

NonComp Date

1/24/2017

Sector

Muni

Print Current
Form

Mail Today's
Report

Open Query

Caller Name

Leonard Johnson

Caller Phone #

208-818-6875

Facility Name

Plummer, City of

Permit ID

ID0022781

NonCompliance Type

Effluent Limit Violation

Violation
Description

Exceedance of daily max for ammonia and E.coli due to freezing temperatures.

Comments

Form ID

1526

Entry Qtr

2017 Q1

Entry Date

1/27/2017

*Daniel
Domingo*

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By	Date of Call	Time of Call	NonComp Date	Sector
Jason Rodriguez	1/12/2017	11:54 AM	1/12/2017	Muni
Caller Name	Unknown		Caller Phone #	208-818-6875
Facility Name	Plummer, City of			
Permit ID	ID0022781	NonCompliance Type	Bypass	

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Violation Description

Bypass sand filters due to freezing temperatures.

Comments

Form ID 1505

Entry Qtr

2017 Q1

Entry Date

1/13/2017

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

10/31/2016

Time of Call

4:00 AM

NonComp Date

10/31/2016

Sector

Muni

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Caller Name

Leonard Johnson

Caller Phone #

208-818-6875

Facility Name

Plummer, City of

Permit ID

ID0022781

NonCompliance Type

Bypass

Violation Description

Phosphorus bypass due to high inflow.

Comments

Form ID

1468

Entry Qtr

2016 Q4

Entry Date

11/1/2016

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

3/14/2016

Time of Call

7:02 AM

NonComp Date

3/13/2016

Sector

Muni

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Caller Name

Lenard Johnson

Caller Phone #

208-818-6875

Facility Name

Plummer, City of

Permit ID

ID0022781

NonCompliance Type

Bypass

Violation Description

Bypassing phosphorus removal due to high flow

Comments

Form ID

1153

Entry Qtr

2016 Q1

Entry Date

3/17/2016

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

3/6/2016

Time of Call

7:53 AM

NonComp Date

3/6/2016

Sector

Muni

Print Current
Form

Mail Today's
Report

Open Query

Caller Name

Leonard Johnson

Caller Phone #

208-818-6875

Facility Name

Plummer, City of

Permit ID

Id0022781

NonCompliance Type

O&M

Violation
Description

High flow due to heavy rain, had to bypass phosphorus treatment.

Comments

Form ID

1142

Entry Qtr

2016 Q1

Entry Date

3/11/2016

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

3/22/2016

Time of Call

3:30 PM

NonComp Date

3/22/2016

Sector

Muni

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Caller Name

Leonard Johnson

Caller Phone #

208-818-6875

Facility Name

Plummer, City of

Permit ID

ID0022781

NonCompliance Type

Bypass

Violation Description

Bypass of phosphorus removal due to high flows

Comments

Form ID

1167

Entry Qtr

2016 Q1

Entry Date

3/28/2016

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

1/26/2016

Time of Call

9:30 AM

NonComp Date

1/26/2016

Sector

Muni

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Caller Name

Jacob Qwals

Caller Phone #

Facility Name

Plummer, City of

Permit ID

ID0022781

NonCompliance Type

Effluent Limit Violation

Violation Description

Ammonia and phosphorus were above the weekly average due to heavy rain and flow.

Comments

Form ID

1106

Entry Qtr

2016 Q1

Entry Date

1/29/2016